



Test Report				Date of issue: 9.6.2014				
				Serial No.:				
				Type:	M3KP 400LC 8			
				Product Code:	3GKP404530- DG			
				Protection type:	Ex de IIB T4 Gb			
				Cert. No.:	LCIE 10 ATEX 3004X / IECEx LCI 04.0032X			
Rating:								
	V	Hz	kW	r/min	A	cos φ	Duty	
3~Motor	690	Y 50	400	744	424	0,82	S1	
Insul.cl.F	400	D 50	400	744	731	0,82	S1	
S1 AMB -20...+40°C	660	Y 50	400	743	438	0,83	S1	
IP55	380	D 50	400	743	761	0,83	S1	
3520 kg	415	D 50	400	744	722	0,80	S1	
	440	D 60	450	893	740	0,83	S1	
Resistance				Insulation resistance at 83,0 °C		Overload		
Line	Ambient: 27,5 °C			7000 MΩ 1000 V		Torque 160 % 15s		
U <sub>1</sub> - V <sub>1</sub>	0,004300 Ω							
U <sub>1</sub> - W <sub>1</sub>	0,004298 Ω							
V <sub>1</sub> - W <sub>1</sub>	0,004302 Ω							
				High-voltage test winding 1900 V		60 s		
Test	Line U[V]	f[Hz]	Input I[A]	P1 [kW]	Output P2 [kW]	n[r/min]	cos φ	η [%]
No-load test	400,0 D	50	259,0	5,070			0,0283	
Locked rotor test	87,2 D	50	731,2	21,532			0,1949	
Temperature-rise test	400,8 D	50	735,26	416,40	400,0	744	0,817	96,1
Temperature rise at rated load.			[°C]	[K]	Method		Measurement method	
Stator winding :			68,9	1	1		Resistance	
Frame :			44,5	3	2		Thermometer	
Bearing D-end :			49,0	3	3		Thermocouples	
Rotor :			120,9	2				
Ambient Temperature :			25,0	2				
<p>These tests have been carried out on motor no. 3GF11069476C, on date 2011-06-10, which is identical in design with the above.</p> <p>Starting current (I<sub>s</sub> / I<sub>N</sub>) : 6,02</p> <p>Manufactured and tested in accordance with rules of IEC 60034-1 and IEC 60034-2-1. PLL determined from residual loss.</p>								
On behalf of customer								
On behalf of manufacturer				Date of test				
Tested by ABB Oy, Motors and Generators, Vaasa, Finland				Telephone +358 10 2211 Telefax +358 10 22 47372				

Computer print-out valid without signature.