

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
 (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product	Fan Coil Controller (FCC)
Name and address of the applicant	ABB STOTZ-KONTAKT GmbH Eppelheimerstraße82 69123 Heidelberg Germany
Name and address of the manufacturer	ABB STOTZ-KONTAKT GmbH Eppelheimerstraße82 69123 Heidelberg Germany
Name and address of the factory	<input type="checkbox"/> Additional information on page 2
Note: When more than one factory, please report on page 2	ABB STOTZ-KONTAKT GmbH Hauptstraße 14-16 78132 Hornberg Germany
Ratings and principal characteristics	input: ABB – ibus KNX - 21...30 Vdc; < 12 mA load side: 23-230 V~; 50/60 Hz; 0,5 A; ε for thermostat valve 230 V~; 50/60 Hz; 16 A; μ for general purpose relay 230 V~; 50/60 Hz; 5 A in total; μ for ventilation relay 0-10 V thermostat valve control
Trademark (if any)	ABB
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	FCC/S 1.1.1.1; FCC/S 1.1.2.1 FCC/S 1.2.1.1; FCC/S 1.2.2.1 FCC/S 1.3.1.1; FCC/S 1.3.2.1 FCC/S 1.4.1.1 FCC/S 1.5.1.1; FCC/S 1.5.2.1
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60669-1:1998, IEC 60669-1:1998/AMD1:1999, IEC 60669-1:1998/AMD2:2006, IEC 60669-2-1:2002, IEC 60669-2-1:2002/AMD1:2008, IEC 60669-2-1:2002/AMD2:2015, IEC 60669-2-5:2013
As shown in the Test Report Ref. No. which forms part of this Certificate	2233043.50

This CB Test Certificate is issued by the National Certification Body

 DEKRA Certification B.V.  
 Meander 1051, NL-6825 MJ Arnhem, Netherlands

