

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit breaker

Name and address of the applicant

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

Name and address of the manufacturer

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

Name and address of the factory

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

☒ Additional Information on page 2230/400 V a.c.;
In = 0,2 ... 63 A; Characteristic B; C; D; K; Z
Icu = 15 kA; Ics = 7,5 / 11,25 kA

Trademark (if any)

ABB

Customer's Testing Facility (CTF) Stage used

CTF Stage 2


Model / Type Ref.

Series SU200M

Additional information (if necessary may also
be reported on page 2)☐ Additional Information on page 2A sample of the product was tested and found
to be in conformity withIEC 60947-1:2007
IEC 60947-1:2007/AMD1:2010
IEC 60947-1:2007/AMD2:2014
IEC 60947-2:2016As shown in the Test Report Ref. No. which
forms part of this Certificate

239972-TL3-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

Date: 2018-04-09

Signature:

J. Richter



Ref. Certif. No.

DE1-60263

ABB Bulgaria EOOD - Rakovski Branch -
Industrial Zone Rakovski Municipality, 4150
RAKOVSKI
BULGARIA

Additional information (if necessary)

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

Date: 2018-04-09

Signature:

J. Richter