



Test Report				Date of issue: 4.6.2014							
				Serial No.: 3GF10039061							
				Type: M3JP 160MLA 6 IMB3/IM1001							
				Product Code: 3GJP163410-ADH							
				Protection type: Ex d IIB T4 Gb							
				Cert. No.: LCIE 11 ATEX 3087X / IECEX LCI 09.0008X							
Rating:				V	Hz	kW	r/min	A	cos φ	Duty	
3~Motor				400	D 50	7,5	965	15,3	0,81	S1	
Insul.cl.F				415	D 50	7,5	968	15,1	0,79	S1	
IP65				690	Y 50	7,5	965	8,9	0,81	S1	
Eff class IE2				50Hz : IE2 - 87.2(100%) - 88.4(75%) - 88.2(50%)							
Resistance				Ambient: 21,0 °C				Insulation resistance at 51,0 °C		Overload	
Line								2400 MΩ 1000 V		Torque 160% 15s	
U ₁ - V ₁				1,08290 Ω							
U ₁ - W ₁				1,08240 Ω							
V ₁ - W ₁				1,08360 Ω							
								High-voltage test winding 1900 V		60 s	
Test	Torque [Nm]	Line U[V]	f[Hz]	Input I[A]	P1 [kW]	Output P2 [kW]	n[r/min]	cos φ	η [%]		
No load test		400,0 D	50	6,99	0,37		1000	0,08			
Locked rotor test		101,6 D	50	15,3	1,06		0	0,39			
Thermal test (100% load)	74,2	400,0 D	50	15,8	8,75	7,50	961	0,80	85,7		
Partial load points:											
~75% load	55,7	400,1 D	50	12,6	6,48	5,62	972	0,74	86,9		
~50% load	37,1	400,1 D	50	9,87	4,33	3,75	983	0,63	86,6		
~25% load	18,6	400,1 D	50	7,84	2,31	1,87	990	0,43	81,2		
Temperature rise at rated load.				[°C]	[K]	Method		Measurement method			
Stator winding :					80,4	1		1 Resistance			
Frame :					26,4	2		2 Thermometer			
Bearing D-end :					27,6	2		3 Thermocouples			
Ambient Temperature :				25,0		2					
Manufactured and tested in accordance with rules of IEC 60034-1 and IEC 60034-2-1. PLL determined from residual loss.											
On behalf of customer											
On behalf of manufacturer				Date of test		29.9.2010					
Tested by ABB Oy, Motors and Generators, Vaasa, Finland								Telephone +358 10 2211		Telefax +358 10 22 47372	

Computer print-out valid without signature.