



中国国家强制性产品认证证书

证书编号: 2003010304060093

委托人名称、地址

ABB France
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

生产者(制造商)名称、地址

ABB France
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

生产企业名称、地址

ABB France
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

产品名称和系列、规格、型号

切换电容器接触器

UA50, UA63, UA75 Ui: 1000V; UA50: Ith: 100A; AC-6b; Ue/Ie:
AC220/230/240/400/415/440/500/550/660/690V/51A; UA63: Ith: 125A; AC-6b; Ue/Ie:
AC220/230/240/400/415/440/500/550/660/690V/66A; UA75: Ith: 125A; AC-6b; Ue/Ie:
AC220/230/240/400/415/440/500/550/660/690V/76A; Us: 24V 50/60Hz, 48V 50/60Hz, 110V
50Hz/110-120V 60Hz, 220-230V 50Hz/230-240V 60Hz, 380-400V 50Hz/400-415V 60Hz, 400-415V
50Hz/415-440V 60Hz; 极数: 3P; 配用辅助触头: CAL5-11 IN01NC Ith: 16A; AC-15; Ue/Ie:
24-127V/6A, 220-240V/4A, 380-440V/3A, 500-690V/2A; DC-13; Ue/Ie: 24V/6A, 48V/2.8A,
72V/1A, 110-125V/0.55A, 220-250V/0.3A;

产品标准和技术要求

GB/T14048.4-2010

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2017年07月04日 有效期至: 2022年07月04日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2003年07月15日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2003010304060093

NAME AND ADDRESS OF THE APPLICANT

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

NAME AND ADDRESS OF THE MANUFACTURER

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

NAME AND ADDRESS OF THE FACTORY

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

PRODUCT NAME, MODEL AND SPECIFICATION

Contactors for capacitor switching

UA50, UA63, UA75 Ui: 1000V; UA50: Ith: 100A; AC-6b: Ue/Ie: AC220/230/240/400/415/440/500/550/660/690V/51A; UA63: Ith: 125A; AC-6b: Ue/Ie: AC220/230/240/400/415/440/500/550/660/690V/66A; UA75: Ith: 125A; AC-6b: Ue/Ie: AC220/230/240/400/415/440/500/550/660/690V/76A; Us: 24V 50/60Hz, 48V 50/60Hz, 110V 50Hz/110-120V 60Hz, 220-230V 50Hz/230-240V 60Hz, 380-400V 50Hz/400-415V 60 Hz, 400-415V 50Hz/415-440V 60Hz; Poles: 3P; Attached Auxiliary Contacts: CAL5-11; 1NO1NC; Ith: 16A; AC-15: Ue/Ie: 24-127V/6A, 220-240V/4A, 380-440V/3A, 500-690V/2A; DC-13: Ue/Ie: 24V/6A, 48V/2.8A, 72V/1A, 110-125V/0.55A, 220-250V/0.3A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.4-2010

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Jul.04,2017

Valid until: Jul.04,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Jul.15,2003

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE