

# CERTIFICATE OF CONFORMITY

**Product:** main switches and disconnectors

**Tested by request of** ABB Oy  
Smart Power  
P.O.Box 622  
65101 VAASA  
Finland

**Manufactured at (name and place)** ABB Oy  
Smart Power  
P.O.Box 622  
65101 VAASA  
Finland

**Trade mark (if any):** ABB

**Model/Type Ref:** Switch disconnectors Series OS32-63

**Ratings and principal characteristics:** /

**Additional information (if any) :** for HVAC applications employing A2L refrigerants with a maximum burning velocity of 1,5 cm/s (corresponding to R454C)

A sample of the product has been tested and found to be in conformity with :

Annex JJ of IEC 60335-2-40:2018

as shown in the test report(s) 63359802/02

This Certificate of Conformity is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard. It does not imply an assessment of the whole production. This Certificate of Conformity has been issued in accordance with the SGS CEBEC certification program CPRStd003, which is available on request. Conformity of the produced products with the specimen tested remains on the full responsibility of the manufacturer.

Brussels, 04/09/2023

  
C. LANA,  
Certification Manager.

SGS



SGS

SGS

SGS

This document is issued by the company under its **General Conditions of Certification Services of SGS Belgium NV** accessible at [http://www.sgs.com/terms\\_and\\_conditions.htm](http://www.sgs.com/terms_and_conditions.htm).  
Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

SGS Belgium NV – Division SGS CEBEC  
Riverside Business Park  
Bld. Internationalelaan, 55 Build. A  
BE-1070 Brussels  
Tel. +32 2 556 00 20  
Fax +32 2 556 00 36