



Type Test Report				Date of issue: 23.11.2015					
				Type: M3JM 315SMA 2					
				Product Code: 3GJM311210-_DG					
				Protection type: Ex d I Mb					
				Cert. No.: LCIE 11 ATEX 3090X /					
				IECEX LCI 04.0007X					
Rating:									
		V	Hz	kW	r/min	A	cos φ	Duty	
3-Motor		690	Y 50	110	2982	112	0,86	S1	
Insul.cl.F		400	D 50	110	2982	197	0,86	S1	
IP66		415	D 50	110	2983	192	0,85	S1	
Eff class IE2		50Hz: IE2 - 94,9%(100%) - 94,4%(75%) - 92,9%(50%)							
Resistance			Insulation resistance at 60 °C			Overload			
Line		Ambient: 22 °C		MΩ		1000 V		Torque 160 % 15s	
U ₁ - V ₁		0,01658 Ω							
U ₁ - W ₁		0,01655 Ω							
V ₁ - W ₁		0,01657 Ω							
				High-voltage test winding		1900 V		60 s	
Test		Line		Input		Output			
		U[V]	f[Hz]	I[A]	P1 [kW]	P2 [kW]	η[r/min]	cos φ	η [%]
No load test		400,0 D	50	62,0	3,29			0,08	
Locked rotor test		62,7 D	50	194,0	5,47		0	0,26	
Thermal test (100% load)		400,0 D	50	196,9	115,8	110,0	2984	0,85	95,0
Partial load points:									
~75% load		400,7 D	50	153,8	87,2	82,5	2989	0,82	94,6
~50% load		400,8 D	50	114,6	58,9	55,0	2993	0,74	93,3
~25% load		401,0 D	50	81,9	31,0	27,5	2997	0,55	88,8
Temperature rise at rated load.		[°C]		[K]		Method		Measurement method	
Stator winding :				56		1		1 Resistance	
Frame :				27		2		2 Thermocouples	
Bearing D-end :				34		2		3 Thermometer	
Ambient Temperature :		25				2			
<p>These tests have been carried out on motor no. 3GP11024793, on date 2011-11-02, which is identical in electrical design with the above.</p> <p>Manufactured and tested in accordance with rules of IEC 60034-1 and IEC 60034-2-1. PLL determined from residual loss.</p> <p>On behalf of customer</p> <p>On behalf of manufacturer</p> <p>Tested by ABB Oy, Motors and Generators, Vaasa, Finland</p> <p>Telephone +358 10 2211 Telefax +358 10 22 47372</p>									

Computer print-out valid without signature.