

Certificate of Compliance

Certificate Number **220108 - E312527A**
Report Reference **E312527, December 12th, 2007**
Issue Date **2008 January 22**

Page 1 of 1



Issued to: **ABB FRANCE**
ACTIVITE PROTECTION ET CONTROL
10 RUE AMPERE 69685 CHASSIEU CEDEX FRANCE

This is to certify that representative samples of

Auxiliary devices.


Auxiliary contacts blocks, open type, Cat. Nos. NS, NSL followed by 2, 3, 4, 5, 6, 7 or 8, followed by 0, 1, 2, 3, 4 may be followed by E, may be followed by S, followed by two digits, may be followed by a letter. Auxiliary contacts blocks, open type, Cat. Nos. CA3 followed by -10 or -01, may be followed by S, may be followed by a letter.

Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized licensee of UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: **UL 508, Industrial control Equipment 17th Edition, December 12, 2002.**
C22.2 No. 14-05, Industrial control Equipment

Additional Information: **ELECTRICAL RATINGS:**
Environment : Pollution Degree 3
Coil Voltages:
24 to 415 V ac, 50/60 Hz
12 to 240 V dc

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *David ROUL*
David ROUL, Project Engineer
Underwriters Laboratories Inc.

Reviewed by: *Matteo Redaelli*
Matteo Redaelli, Engineering Group Leader
Underwriters Laboratories Inc.