



中国国家强制性产品认证证书

证书编号：2004010304138317

委托人名称、地址

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

生产者（制造商）名称、地址

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

生产企业名称、地址

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

产品名称和系列、规格、型号

接触器

TAL26-30, TAL26-30... RT, TAL26-40, TAL26-22; 详见参数附件

产品标准和技术要求

GB/T14048. 4-2010

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，
特发此证。

发证日期：2017年08月21日 有效期至：2022年08月21日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2004年12月28日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任：



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2004010304138317

NAME AND ADDRESS OF THE APPLICANT

ABB France
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

NAME AND ADDRESS OF THE MANUFACTURER

ABB France
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

NAME AND ADDRESS OF THE FACTORY

ABB France
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

PRODUCT NAME, MODEL AND SPECIFICATION

Contactor
TAL26-30,TAL26-30...RT,TAL26-40,TAL26-22;See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.4-2010

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Aug.21,2017

Valid until: Aug.21,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Dec.28,2004

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2004010304138317

纸号: 1778892

TAL26-30, TAL26-30...RT, TAL26-40, TAL26-22

Ui:1000V(690V for TAL RT);

Ith:45A;

AC-1:Ue/Ie:690V/45A;

AC-3:Ue/Ie:220-230-240/380-400/415/440V/26A,500V/22A,690V/13A;

AC-4:Ue/Ie:220-230-240/380-400/415/440V/26A,500V/17A,690V/10.6A;

AC-8a:Ue/Ie:400V/30A;

Us:DC17-32V;

3P,4P;

IP20(IP10 for TAL RT);

配用辅助触头:(本体)

1NO/1NC

Ith:16A;

AC-15:Ue/Ie:24-127V/6A,220-240V/4A,380-440V/3A,500-690V/2A;

DC-13:Ue/Ie:24V/6A,48V/2.8A,72V/2A,110-125V/1.1A,220-250V/0.55A

注: 此附录与证书同时使用时有效。



主任:



中国质量认证中心



中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2004010304138317

纸号: 1778892

型号的解释:

TAL26 30 10 RT

I II III IV V VI

I - Main designation: TAL

II - Range size

26

III - Main Pole Construction

22 - 2 Normally Opened and 2 Normally Closed main poles.

30 - 3 Normally Opened and 0 Normally Closed main poles.

40 - 4 Normally Opened and 0 Normally Closed main poles.

IV - Auxiliary Pole Construction

00 - No auxiliary pole provided.

01 - 1 normally closed auxiliary pole provided.

10 - 1 Normally opened auxiliary pole provided.

V - Connection type

Blank = Screw type connection

RT = Ring Tong terminal

VI - Coil code

See table 1

List of type

Designation
TAL26-30-10 + coil voltage
TAL26-30-01 + coil voltage
TAL26-30-10RT + coil voltage
TAL26-30-01RT + coil voltage
TAL26-40-00 + coil voltage
TAL26-22-00 + coil voltage

注: 此附录与证书同时使用时有效。



主任:



中国质量认证中心