



Ref. Certif. No.
DE1-59528

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Power supply unit


ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

ABB STOTZ-KONTAKT GmbH Werk Hornberg
Hauptstrasse 14-16, 78132 Hornberg
GERMANY

Additional Information on page 2

Input: AC 100 - 240 V, 50/60 Hz
Output: DC 30 V (SELV) for KNX-Bus systems



SV/S 30.640.5.1, SV/S 30.320.2.1
SV/S 30.640.3.1, SV/S 30.320.1.1
SV/S 30.160.1.1, SV/S 30.200.3.1
PS-M-64.1.1

Additional Information on page 2

IEC 61558-1:2005
IEC 61558-1:2005/AMD1:2009
IEC 61558-2-16:2009
IEC 61558-2-16:2009/AMD1:2013

70000-3310-0001/237251

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

Date: 2017-10-26

Signature: 
H. König