

REVISIONS

REV	DESCRIPTION	DATE	APPROVED
1	9800240C	6-22-98	
2	R0814582	MSM 03-31-08	

 **GE PowerMark Gold™ Auxillary Gutter**  **LISTED CONTROL NO. 48PA AUXILIARY GUTTER**

Type 1 Indoor Enclosure
Cat. No.: **TMAGB33**

Use only GE type Tap Kits: **TMGT250 or TMGT500**

1 PHASE OR 3 PHASE 240 VOLT MAXIMUM

SUITABLE FOR USE ON A CIRCUIT CAPABLE OF DELIVERING NOT MORE THAN 65,000 RMS SYMMETRICAL AMPERES AT 240 V.A.C. MAXIMUM.

ONLY FEED-THRU AND PARALLEL TAP CONNECTORS LISTED BELOW ARE TO BE ACCOMODATED IN THIS ENCLOSURE. SUITABLE FOR USE IN ALL GE LOAD CENTERS. TAP KIT ASSEMBLIES ARE ORDERED SEPARATELY.

ACCEPTABLE GUTTER TAP KITS:	MAIN	TAP
TMGT250	250-1/0	250-6
TMGT500	500-350	500-02

TAP KIT INSTRUCTIONS:

TAP LUGS TERMINATIONS REQUIRED WITHIN 18 INCHES OF THE FEED-IN SIDE OF THE AUXILIARY GUTTER.

1. STRIP WIRE PER GAUGE ON PROTECTIVE COVER, SPACING CUTS A MINIMUM OF 2 1/2 INCHES APART. MAKE MAIN AND TAP CONNECTIONS.
2. TORQUE REQUIREMENTS:
TMGT250 - 325 IN.LBS.; TMGT500 - 375 IN.LBS.
3. PLACE CONNECTOR WITH WIRES INTO THE PROTECTIVE COVER.
4. SNAP PROTECTIVE COVER CLOSED.

NOTE: BUSHING COUPLER AND MOUNTING BOLTS MUST BE INSTALLED PER INSTRUCTION SHEET PRIOR TO WIRE INSTALLATION.


10080802P3 Plainville, CT 06062 ASSEMBLED IN MEXICO

P3

MAT'L: C50HD15A
SIZE: 5.00 X 5.00

GE (USA) CONFIDENTIAL AND PROPRIETARY
THIS GE DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF GE ELECTRICAL DISTRIBUTION & CONTROL (ED&C). IT IS LOANED ON CONDITION THAT IT AND THE INFORMATION THEREIN SHALL NOT BE USED BY RECIPIENT NOR DISCLOSED TO OTHERS EXCEPT AS EXPRESSLY APPROVED BY ED&C. ANY DOCUMENT CONTAINING SUCH INFORMATION SHALL BE RETURNED ON REQUEST.

THIRD ANGLE PROJECTION



FOR ADDITIONAL INFO REFER TO	SIGNATURES	DATE
APPLIED PRACTICES	DRAWN JFN	6-22-98
UNLESS OTHERWISE SPECIFIED	CHECKED	
DIMENSIONS ARE IN INCHES	ENGRG	
TOLERANCES ON:	MFG	
PL DECIMALS ±	QUALITY	
PL DECIMALS ±	ISSUED	
ANGLES ±		
FRACTIONS ±		

 **GE Consumer & Industrial**

TITLE
RATING LABEL

FIRST MADE FOR
DRAWING FILE 10080802P3.tif SIZE A CAGE CODE DWG NO 10080802

⊖ CRITICAL TO QUALITY CHARACTERISTIC

SCALE NTS SHEET 1 OF 1