



# 产品认证证书

证书编号：CQC2014010303720193

申请人名称及地址

ABB Stotz-Kontakt GmbH  
Eppelheimer Strasse 82 69123 Heidelberg Germany

制造商名称及地址

ABB Stotz-Kontakt GmbH  
Hauptstrasse 14-16, D-78132 Hornberg, Germany

生产企业名称及地址

Relpol S. A. (V055275)  
ul.11 Listopada 37, 68-200 Zary, Poland

产品名称和系列、规格、型号

继电器

CR-M(型号解释详见附件); Uimp:4kV(2P,3P),2.5kV(4P); Ui:300V; Ith:12A(2P),10A(3P),6A(4P);  
Ue/Ie:AC-15:AC240V/1.5A(2P,3P),AC240V/1.0A(4P); IP40(操作面)

产品标准和技术要求

GB/T 14048.5-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求，特发此证。

发证日期：2020年09月08日 有效期至：2024年08月19日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任：

陆梅



## 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0370624



# PRODUCT CERTIFICATE

**CERTIFICATE NO.:** CQC2014010303720193

**NAME AND ADDRESS OF THE APPLICANT**

ABB Stotz-Kontakt GmbH  
Eppelheimer Strasse 82 69123 Heidelberg Germany

**NAME AND ADDRESS OF THE MANUFACTURER**

ABB Stotz-Kontakt GmbH  
Hauptstrasse 14-16, D-78132 Hornberg, Germany

**NAME AND ADDRESS OF THE FACTORY**

Relpol S.A. (V055275)  
ul.11 Listopada 37, 68-200 Zary, Poland

**PRODUCT NAME, MODEL AND SPECIFICATION**

Relays

CR-M; Uimp:4kV(2P,3P),2.5kV(4P); Ui:300V; Ith:12A(2P),10A(3P),6A(4P);  
Ue/Ie:AC-15:AC240V/1.5A(2P,3P),AC240V/1.0A(4P); IP40(above operating surface)

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T 14048.5-2017

**TYPE OF CERTIFICATION SCHEMES**

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Sep.08,2020

Valid until: Aug.19,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

**President:** \_\_\_\_\_

Lu Mei



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China  
<http://www.cqc.com.cn>

C 0370624



# 产品认证证书

附录

第 1 页 共 1 页

证书编号: CQC2014010303720193

纸号: 370624

型号的解释:

CR-M 024DC 3 L  
① ② ③ ④

① basic model (基本型号)

② coil voltage (线圈电压) 012DC,024DC,048DC,060DC,110DC,125DC,220DC  
024AC,048AC,110AC,120AC,230AC;

③ number of poles(极数): 2, 3, 4;

④ accessories: (附件)

NULL - general relay without any accessories 一般继电器, 不带任何附件

L - with LED 带 LED

LG: with LED and gold plated contacts 带 LED 和镀金触点

LD: with LED and freewheeling diode 带 LED 和续流二极管保护

注: 此附录与证书同时使用时有效。

主任: \_\_\_\_\_

陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>